

DVGW-Baumusterprüfzertifikat

DVGW type examination certificate

DW-8501AS2288

Registriernummer
registration number

Anwendungsbereich <i>field of application</i>	Produkte der Wasserversorgung <i>products of water supply</i>
Zertifikatinhaber <i>owner of certificate</i>	POLOPLAST GmbH Kirnachstraße 17, D-87640 Ebenhofen
Vertreiber <i>distributor</i>	POLOPLAST GmbH Kirnachstraße 17, D-87640 Ebenhofen
Produktart <i>product category</i>	installation systems with special pipes: drinking water installation systems (8801)
Produktbezeichnung <i>product description</i>	drinking water installation system consisting of pipes made of plastic (PP-R 80) and fittings made of plastic (PP-R 80)
Modell <i>model</i>	POLYMUTAN
Prüfberichte <i>test reports</i>	mechanical test: 96908/2.4/84165 from 02.12.2008 (SKZ) mechanical test: 96908/2.3/84164 from 02.12.2008 (SKZ) mechanical test: 96908/2.2/84163 from 02.12.2008 (SKZ) mechanical test: 51309/1.1/86365 from 08.06.2009 (SKZ) KTW testing: KR 036/09 from 12.05.2009 (TZW) KTW testing: KR 030/09 from 17.06.2009 (TZW) hygienic testing: M146/06 from 30.07.2006 (TZW)
Prüfgrundlagen <i>basis of type examination</i>	DVGW W 534 (01.05.2004) DVGW W 544 (01.05.2007) UBA KTW (16.05.2007) DVGW W 270 (01.11.2007)
Ablaufdatum / AZ <i>date of expiry / file no.</i>	12.07.2014 / 09-0343-WNV

09.07.2009 GI A-1/2

Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle
date, issued by, sheet, head of certification body

DVGW CERT GmbH - von der Deutschen Akkreditierungsstelle Technik (DATech)
in der TGA GmbH akkreditiert für die Konformitätsbewertung von Produkten der
Gas- und Wasserversorgung

DVGW CERT GmbH - accredited by Deutsche Akkreditierungsstelle Technik
(DATech) in the TGA GmbH for conformity assessment of products of gas and
water supply



DAT-ZE-009/96-02

DVGW CERT GmbH
Josef-Wirmer-Straße 1-3
53123 Bonn

Telefon: +49 228 91 88-888
Telefax: +49 228 91 88-993
eMail: info@dvw-cert.com

Typ <i>type</i>	Technische Daten <i>technical data</i>	Bemerkungen <i>remarks</i>
POLYMUTAN	diameter: 16 mm	
POLYMUTAN	diameter: 20 mm	
POLYMUTAN	diameter: 25 mm	
POLYMUTAN	diameter: 32 mm	
POLYMUTAN	diameter: 40 mm	
POLYMUTAN	diameter: 50 mm	
POLYMUTAN	diameter: 63 mm	

Verwendungshinweise / Bemerkungen***hints of utilization / remarks***

plastic pipe to use: PP-R 80, Poloplast GmbH, D - 87640 Ebenhofen
Connector to use: plastic, type S-KK, PP-R 80, Poloplast, D - 87640 Ebenhofen

Self-sealing plastic-threads are not part of this certification.

With the test report M146/06 (TZW) date: 30.07.2006 it is proven, that the requirements according the standard DVGW W270 (01.11.2007) appendix A.1.1:

"Material for the standard application in contact with potable water " are fulfilled.